



**VICTORIA UNIVERSITY**  
MELBOURNE AUSTRALIA

*Integrated fault estimation and accommodation design for discrete-time Takagi-Sugeno fuzzy systems with actuator faults*

This is the Published version of the following publication

Jiang, Bin, Zhang, Ke and Shi, Peng (2011) Integrated fault estimation and accommodation design for discrete-time Takagi-Sugeno fuzzy systems with actuator faults. IEEE Transactions on Fuzzy Systems, 19 (2). pp. 291-304. ISSN 1063-6706

The publisher's official version can be found at  
<http://dx.doi.org/10.1109/TFUZZ.2010.2095861>

Note that access to this version may require subscription.

Downloaded from VU Research Repository <https://vuir.vu.edu.au/7208/>

# Integrated Fault Estimation and Accommodation Design for Discrete-Time Takagi-Sugeno Fuzzy Systems with Actuator Faults

Bin Jiang, *Senior Member, IEEE*, Ke Zhang, and Peng Shi, *Senior Member, IEEE*

**Abstract**—This paper addresses the problem of integrated robust fault estimation (FE) and accommodation for discrete-time Takagi-Sugeno (T-S) fuzzy systems. First, a multiconstrained reduced-order FE observer (RFE0) is proposed to achieve FE for discrete-time T-S fuzzy models with actuator faults. Based on the RFE0, a new fault estimator is constructed. Then, using the information of on-line FE, a new approach for fault accommodation based on fuzzy dynamic output feedback is designed to compensate for the effect of faults by stabilizing the closed-loop systems. Moreover, the RFE0 and the dynamic output feedback fault tolerant controller are designed separately, such that their design parameters can be calculated readily. Simulation results are presented to illustrate our contributions.

**Index Terms**—Fault estimation, fault accommodation, T-S fuzzy models, discrete-time systems.

## I. INTRODUCTION

The demand for increased productivity leads to more challenging operating conditions for many practical engineering systems. Such conditions would increase the possibility of system failures. Sensor, actuator or component failures may drastically change the system behavior, resulting in degradation or even instability. In order to improve efficiency, the reliability can be achieved by fault detection and isolation (FDI) and fault tolerant control (FTC), so FDI and FTC have been the subjects of intensive investigations over the past two decades. Fruitful results can be found in several excellent books [1]–[3], survey papers [4]–[6] and the references therein.

Since most practical systems are nonlinear in nature, FDI/FTC applications to industrial and commercial processes need nonlinear models to be specifically considered. Takagi-Sugeno (T-S) fuzzy models are based on a set of if-then rules which give a local linear representation of an underlying nonlinear system and it is well-known that such models can describe or approximate a class of nonlinear systems. Therefore, they have attracted considerable attention and given

rise to many important results in the past decades [7]–[19]. However, note that most address stability analysis and feedback stabilization, and very few address the issues of fault estimation (FE) and accommodation.

For discrete-time systems, the topic on fault detection has attracted considerable attention [20]–[24], but FDI is only the first step in fault accommodation (FA). FE is utilized to on-line determine the magnitude of the fault, but this is not an easy task. Compared with fault detection, FE is more challenging and has motivated few attention for discrete-time systems. Furthermore, using the obtained fault information, the FA module can be used to compensate for the effect of the fault, so it is shown that the issue of FE is more meaningful and challenging. Meanwhile, most continuous-time control systems being implemented digitally, FE design for discrete-time cases is more practical, but it has motivated few attention. A learning approximation approach proposed in [25], [26] assumed the occurred faults belonged to a special structure and did not consider FE performance. The problem of FE filter was dealt with in [24], [27], but the filter design was only suitable for open-loop stable systems. In practical situations, most of systems are open-loop unstable, so such a constraint limits its application scopes. In [28], [29], one FE method based on a special coordinate transformation was studied, but the assumption that  $\text{rank}(C_i B_i)$  are of full-column rank was required. Also, the on-line fault estimate at time  $k$  needed the output vector at time  $k + 1$ . Due to the introduction of an estimation delay, such a case could be not suitable for practical situations. In [30], [31], the given proportional integral observer could realize constant unknown input estimation by constructing augmented systems, but the estimation performance was not considered.

Based on the above works, our objective of this paper is to analyze and develop a general framework of robust FE and accommodation for discrete-time T-S fuzzy systems with actuator faults. The main contributions of this paper are summarized in three aspects.

–First, a multiconstrained fuzzy reduced-order FE observer (RFE0) including an  $H_\infty$  performance level and a regional pole constraint is proposed, not only to guarantee the convergence speed of FE, but also to attenuate the influence of disturbances as much as possible.

–Second, compared with the FE methods in [28], [29], the proposed RFE0 design has a wider application range, and uses the current output information to enhance FE performances.

–Third, using the on-line fault estimate, a discrete-time

This work is partially supported by the National Natural Science Foundation of China (61034005, 60804011, 60904001), the NUAU Research Funding (NZ2010003), the Engineering and Physical Sciences Research Council of UK (EP/F029195) and the Graduate Research and Innovation Project of Jiangsu Province (CX08B\_090Z).

B. Jiang and K. Zhang are with College of Automation Engineering, Nanjing University of Aeronautics and Astronautics, Nanjing 210016, P.R. China. E-mail: binjiang@nuaa.edu.cn; kezhang@nuaa.edu.cn.

P. Shi is with Department of Computing and Mathematical Sciences, University of Glamorgan, Pontypridd, CF37 1DL, UK, and also with School of Engineering and Science, Victoria University, Melbourne, Vic 8001, Australia, and School of Mathematics and Statistics, University of South Australia, Adelaide, 5095, SA, Australia. E-mail: pshi@glam.ac.uk.

Manuscript received April 19, 2005; revised January 11, 2007.

fuzzy dynamic output feedback fault tolerant controller (DOFFTC) is designed to guarantee the system stability in the presence of actuator faults.

In the whole design process, the RFEO and the DOFFTC are designed separately and their performances are considered simultaneously, which is convenient to calculate design parameters.

The rest of this paper is organized as follows. Section 2 presents the system description. In Section 3, a fuzzy RFEO design including an  $H_\infty$  performance index and a regional pole constraint is proposed to estimate the fault vector. Furthermore, in Section 4, based on the on-line fault estimate, a new FA design is proposed to compensate for the effect of faults. Simulation results of a discrete-time nonlinear truck-trailer model are presented to illustrate the effectiveness of the proposed method in Section 5, followed by some concluding remarks in Section 6.

## II. SYSTEM DESCRIPTION

The T-S fuzzy model is described by fuzzy IF-THEN rules, whose collection represent the approximation of the nonlinear system. The  $i$ th rule of the T-S fuzzy model is of the following form.

*Plant Rule  $i$ :*

IF  $\vartheta_1(k)$  is  $\pi_{i1}$  and  $\dots$  and  $\vartheta_s(k)$  is  $\pi_{is}$ , THEN

$$x(k+1) = A_i x(k) + B_i(u(k) + f(k)) + D_i \omega(k), \quad (1)$$

$$y(k) = C_i x(k), \quad (2)$$

$$z_L(k) = C_{Li} x(k), \quad (3)$$

where  $x(k) \in \mathbb{R}^n$  is the state,  $u(k) \in \mathbb{R}^m$  is the input,  $y(k) \in \mathbb{R}^p$  is the measurable output,  $z_L(k) \in \mathbb{R}^l$  is the controlled output,  $f(k) \in \mathbb{R}^m$  represents the additive actuator fault, and  $\omega(k) \in \mathbb{R}^d$  is the disturbance which is assumed to belong to  $l_2[0, \infty)$ . The number of measurable output channels is greater than or equal to the number of input ones, i.e.  $p \geq m$ .  $A_i$ ,  $B_i$ ,  $C_i$ ,  $C_{Li}$  and  $D_i$  are constant real matrices of appropriate dimensions. It is supposed that matrices  $B_i$  and  $C_i$  are of full rank, i.e.  $\text{rank}(B_i) = m$  and  $\text{rank}(C_i) = p$ , and the pairs  $(A_i, B_i)$  and  $(A_i, C_i)$  are respectively controllable and observable.  $\vartheta_j(k)$  ( $j = 1, \dots, s$ ) are the premise variables,  $\pi_{ij}$  ( $i = 1, \dots, q; j = 1, \dots, s$ ) are the fuzzy sets that are characterized by membership function,  $q$  is the number of IF-THEN rules and  $s$  is the number of the premise variables. The overall fuzzy model achieved by fuzzy blending of each individual plant rule (local model) is given by

$$x(k+1) = \sum_{i=1}^q h_i(\vartheta(k)) \left[ A_i x(k) + B_i(u(k) + f(k)) + D_i \omega(k) \right], \quad (4)$$

$$y(k) = \sum_{i=1}^q h_i(\vartheta(k)) C_i x(k), \quad (5)$$

$$z_L(k) = \sum_{i=1}^q h_i(\vartheta(k)) C_{Li} x(k), \quad (6)$$

where

$$\vartheta(k) = [\vartheta_1(k), \dots, \vartheta_s(k)], \quad h_i(\vartheta(k)) = \frac{\sigma_i(\vartheta(k))}{\sum_{i=1}^q \sigma_i(\vartheta(k))},$$

$$\sigma_i(\vartheta(k)) = \prod_{j=1}^s \pi_{ij}(\vartheta_j(k))$$

and  $\pi_{ij}(\cdot)$  is the grade of the membership function of  $\pi_{ij}$ . We assume

$$\sigma_i(\vartheta(k)) \geq 0, \quad i = 1, \dots, q, \quad \sum_{i=1}^q \sigma_i(\vartheta(k)) > 0 \quad (7)$$

for any  $\vartheta(k)$ . Hence  $h_i(k)$  satisfies

$$h_i(\vartheta(k)) \geq 0, \quad i = 1, \dots, q, \quad \sum_{i=1}^q h_i(\vartheta(k)) = 1 \quad (8)$$

for any  $\vartheta(k)$ .

For simplicity, we introduce the following notations:

$$h_i = h_i(\vartheta(k)), \quad A(h) = \sum_{i=1}^q h_i(\vartheta(k)) A_i,$$

$$B(h) = \sum_{i=1}^q h_i(\vartheta(k)) B_i, \quad D(h) = \sum_{i=1}^q h_i(\vartheta(k)) D_i,$$

$$C(h) = \sum_{i=1}^q h_i(\vartheta(k)) C_i, \quad C_L(h) = \sum_{i=1}^q h_i(\vartheta(k)) C_{Li},$$

then the T-S fuzzy model (4)–(6) can be rewritten as

$$x(k+1) = A(h)x(k) + B(h)(u(k) + f(k)) + D(h)\omega(k), \quad (9)$$

$$y(k) = C(h)x(k), \quad (10)$$

$$z_L(k) = C_L(h)x(k). \quad (11)$$

**Assumption 1.** For the measurable output matrices,  $C := C_1 = C_2 = \dots = C_q$ .

**Remark 1.** In many practical systems, since the measurable output usually is a part of the states, which means that the measurable output matrices would be common for each local model. Assumption 1 is not very restrictive and widely used in T-S fuzzy systems [15], [32].

Under Assumption 1, the T-S fuzzy model (9)–(11) can be expressed as

$$x(k+1) = A(h)x(k) + B(h)(u(k) + f(k)) + D(h)\omega(k), \quad (12)$$

$$y(k) = Cx(k), \quad (13)$$

$$z_L(k) = C_L(h)x(k). \quad (14)$$

**Remark 2.** In this paper, we only focus on a class of additive actuator faults, for the sake of clarity. However, please note that such kind of additive actuator faults considered in this paper can be readily extended to general class of additive faults [1], [33]. Meanwhile, the additive faults representation is more general than the multiplicative ones, which can be modelled as additive actuator ones [3].

Before ending this section, the following lemma, which will be used to present our main results, is recalled.

**Lemma 1 [34].** The eigenvalues of a given matrix  $\mathcal{A} \in \mathbb{R}^{n \times n}$  belong to the closed circular region  $\mathcal{D}(\alpha, \tau)$  with center  $\alpha + j0$  and radius  $\tau$  if and only if there exists a symmetric positive definite matrix  $\mathcal{P} \in \mathbb{R}^{n \times n}$  such that the following condition holds:

$$\begin{bmatrix} -\mathcal{P} & \mathcal{P}(\mathcal{A} - \alpha I_n) \\ * & -\tau^2 \mathcal{P} \end{bmatrix} \leq 0, \quad (15)$$

where here and everywhere in the sequel,  $*$  denotes the symmetric elements in a symmetric matrix.

### III. FAULT ESTIMATION DESIGN

#### A. State transformation

Note that since  $C$  is of full-row rank, there always exists a matrix  $C^\perp \in \mathbb{R}^{(n-p) \times n}$  such that  $\begin{bmatrix} C^\perp \\ C \end{bmatrix} \in \mathbb{R}^{n \times n}$  is nonsingular (indeed  $C^\perp$  can be chosen as an orthogonal basis of the null-space of  $C$ ). Then under the coordinate transformation  $x(k) = Tz(k)$ , where  $T = \begin{bmatrix} C^\perp \\ C \end{bmatrix}^{-1}$ , the dynamics (12) and (13) can be decomposed into the following form:

$$\begin{bmatrix} z_1(k+1) \\ z_2(k+1) \end{bmatrix} = \sum_{i=1}^q h_i \left\{ \begin{bmatrix} A_{11i} & A_{12i} \\ A_{21i} & A_{22i} \end{bmatrix} \begin{bmatrix} z_1(k) \\ z_2(k) \end{bmatrix} + \begin{bmatrix} B_{1i} \\ B_{2i} \end{bmatrix} (u(k) + f(k)) + \begin{bmatrix} D_{1i} \\ D_{2i} \end{bmatrix} \omega(k) \right\}, \quad (16)$$

$$y(k) = \begin{bmatrix} 0_{p \times (n-p)} & I_p \end{bmatrix} \begin{bmatrix} z_1(k) \\ z_2(k) \end{bmatrix}, \quad (17)$$

where  $z_1(k) \in \mathbb{R}^{n-p}$  and  $z_2(k) \in \mathbb{R}^p$  are new state vectors, and

$$\begin{aligned} z(k) &= \begin{bmatrix} z_1(k) \\ z_2(k) \end{bmatrix}, \quad T^{-1}A_iT = \begin{bmatrix} A_{11i} & A_{12i} \\ A_{21i} & A_{22i} \end{bmatrix}, \\ T^{-1}B_i &= \begin{bmatrix} B_{1i} \\ B_{2i} \end{bmatrix}, \quad T^{-1}D_i = \begin{bmatrix} D_{1i} \\ D_{2i} \end{bmatrix}, \\ CT &= \begin{bmatrix} 0_{p \times (n-p)} & I_p \end{bmatrix}. \end{aligned}$$

Let

$$\begin{aligned} A_{11}(h) &= \sum_{i=1}^q h_i A_{11i}, & A_{12}(h) &= \sum_{i=1}^q h_i A_{12i}, \\ A_{21}(h) &= \sum_{i=1}^q h_i A_{21i}, & A_{22}(h) &= \sum_{i=1}^q h_i A_{22i}, \\ B_1(h) &= \sum_{i=1}^q h_i B_{1i}, & B_2(h) &= \sum_{i=1}^q h_i B_{2i}, \\ D_1(h) &= \sum_{i=1}^q h_i D_{1i}, & D_2(h) &= \sum_{i=1}^q h_i D_{2i}, \end{aligned}$$

then it follows that

$$\begin{bmatrix} z_1(k+1) \\ z_2(k+1) \end{bmatrix} = \begin{bmatrix} A_{11}(h) & A_{12}(h) \\ A_{21}(h) & A_{22}(h) \end{bmatrix} \begin{bmatrix} z_1(k) \\ z_2(k) \end{bmatrix} + \begin{bmatrix} B_1(h) \\ B_2(h) \end{bmatrix} (u(k) + f(k)) + \begin{bmatrix} D_1(h) \\ D_2(h) \end{bmatrix} \omega(k), \quad (18)$$

$$y(k) = \begin{bmatrix} 0_{p \times (n-p)} & I_p \end{bmatrix} \begin{bmatrix} z_1(k) \\ z_2(k) \end{bmatrix}, \quad (19)$$

which can be rewritten as

$$\begin{aligned} z_1(k+1) &= A_{11}(h)z_1(k) + A_{12}(h)y(k) + B_1(h)u(k) + \\ &\quad B_1(h)f(k) + D_1(h)\omega(k), \end{aligned} \quad (20)$$

$$\begin{aligned} y(k+1) &= A_{21}(h)z_1(k) + A_{22}(h)y(k) + B_2(h)u(k) + \\ &\quad B_2(h)f(k) + D_2(h)\omega(k). \end{aligned} \quad (21)$$

By introducing the virtual input and output vectors  $\eta(k)$  and  $\rho(k)$

$$\begin{aligned} \eta(k) &= A_{12}(h)y(k) + B_1(h)u(k), \\ \rho(k) &= y(k+1) - A_{22}(h)y(k) - B_2(h)u(k), \end{aligned}$$

one gets

$$\begin{aligned} z_1(k+1) &= A_{11}(h)z_1(k) + \eta(k) + B_1(h)f(k) + \\ &\quad D_1(h)\omega(k), \end{aligned} \quad (22)$$

$$\rho(k) = A_{21}(h)z_1(k) + B_2(h)f(k) + D_2(h)\omega(k). \quad (23)$$

#### B. RFEO design

For the dynamics (22) and (23), we construct the following fuzzy RFEO:

$$\begin{aligned} \hat{z}_1(k+1) &= A_{11}(h)\hat{z}_1(k) + \eta(k) + B_1(h)\hat{f}(k) - \\ &\quad G(h)(\hat{\rho}(k) - \rho(k)), \end{aligned} \quad (24)$$

$$\hat{\rho}(k) = A_{21}(h)\hat{z}_1(k) + B_2(h)\hat{f}(k), \quad (25)$$

$$\hat{f}(k+1) = \hat{f}(k) - F(h)(\hat{\rho}(k) - \rho(k)), \quad (26)$$

where  $\hat{z}_1(k) \in \mathbb{R}^{n-p}$  is the reduced-order observer state,  $\hat{\rho}(k) \in \mathbb{R}^p$  is the reduced-order observer output,  $\hat{f}(k) \in \mathbb{R}^m$  is an estimate of  $f(k)$ , and  $G(h) \in \mathbb{R}^{(n-p) \times p}$ ,  $F(h) \in \mathbb{R}^{m \times p}$  are reduced-order observer gain matrices to be designed,  $G(h) = \sum_{i=1}^q h_i G_i$ ,  $F(h) = \sum_{i=1}^q h_i F_i$ .

Let  $e_{z1}(k) = \hat{z}_1(k) - z_1(k)$  and  $e_f(k) = \hat{f}(k) - f(k)$ , then the error dynamics is given by

$$\begin{aligned} e_{z1}(k+1) &= (A_{11}(h) - G(h)A_{21}(h))e_{z1}(k) + \\ &\quad (B_1(h) - G(h)B_2(h))e_f(k) + \\ &\quad (G(h)D_2(h) - D_1(h))\omega(k), \end{aligned} \quad (27)$$

$$\begin{aligned} e_f(k+1) &= \hat{f}(k) - F(h)A_{21}(h)e_{z1}(k) - F(h)B_2(h)e_f(k) + \\ &\quad F(h)D_2(h)\omega(k) - f(k+1) \\ &= \hat{f}(k) - f(k) + f(k) - F(h)A_{21}(h)e_{z1}(k) - \\ &\quad F(h)B_2(h)e_f(k) + F(h)D_2(h)\omega(k) - f(k+1) \\ &= e_f(k) - F(h)A_{21}(h)e_{z1}(k) - \\ &\quad F(h)B_2(h)e_f(k) + F(h)D_2(h)\omega(k) - \Delta f(k) \\ &= -F(h)A_{21}(h)e_{z1}(k) + \\ &\quad (I_m - F(h)B_2(h))e_f(k) + F(h)D_2(h)\omega(k) - \\ &\quad \Delta f(k), \end{aligned} \quad (28)$$

where  $\Delta f(k) = f(k+1) - f(k)$  is the fault increment at time  $k$ . Using (27) and (28), the following augmented system

is obtained:

$$\begin{bmatrix} e_{z1}(k+1) \\ e_f(k+1) \end{bmatrix} = \begin{bmatrix} A_{11}(h) - G(h)A_{21}(h) & B_1(h) - G(h)B_2(h) \\ -F(h)A_{21}(h) & I_m - F(h)B_2(h) \end{bmatrix} \times \begin{bmatrix} e_{z1}(k) \\ e_f(k) \end{bmatrix} + \begin{bmatrix} G(h)D_2(h) - D_1(h) & 0_{(n-p) \times m} \\ F(h)D_2(h) & -I_m \end{bmatrix} \begin{bmatrix} \omega(k) \\ \Delta f(k) \end{bmatrix}. \quad (29)$$

Denote

$$\begin{aligned} \bar{e}(k) &= \begin{bmatrix} e_{z1}(k) \\ e_f(k) \end{bmatrix}, \quad \nu(k) = \begin{bmatrix} \omega(k) \\ \Delta f(k) \end{bmatrix}, \\ \bar{A}_{11}(h) &= \begin{bmatrix} A_{11}(h) & B_1(h) \\ 0_{m \times (n-p)} & I_m \end{bmatrix}, \\ \bar{A}_{21}(h) &= \begin{bmatrix} A_{21}(h) & B_2(h) \end{bmatrix}, \quad \bar{G}(h) = \begin{bmatrix} G(h) \\ F(h) \end{bmatrix}, \\ \bar{D}_1(h) &= \begin{bmatrix} D_1(h) & 0_{(n-p) \times m} \\ 0_{m \times d} & I_m \end{bmatrix}, \\ \bar{D}_2(h) &= \begin{bmatrix} D_2(h) & 0_{p \times m} \end{bmatrix}, \end{aligned}$$

then the augmented system becomes

$$\bar{e}(k+1) = (\bar{A}_{11}(h) - \bar{G}(h)\bar{A}_{21}(h))\bar{e}(k) + (\bar{G}(h)\bar{D}_2(h) - \bar{D}_1(h))\nu(k). \quad (30)$$

Next, a RFEO design method under an  $H_\infty$  performance index and a regional pole constraint is proposed to achieve robust FE.

**Theorem 1.** Let a prescribed  $H_\infty$  performance level  $\gamma_1$  and a circular region  $\mathcal{D}(\alpha_1, \tau_1)$  be given. If there exists a symmetric positive definite matrix  $\bar{P} \in \mathbb{R}^{(n+m-p) \times (n+m-p)}$ ; matrices  $\bar{Y}_i \in \mathbb{R}^{(n+m-p) \times p}$  ( $i = 1, \dots, q$ ); matrices with appropriate dimensions  $\mathbb{M}_{iii}, \mathbb{N}_{iii}$  ( $i = 1, \dots, q$ );  $\mathbb{M}_{jii} = \mathbb{M}_{ijj}^T$ ,  $\mathbb{N}_{jii} = \mathbb{N}_{ijj}^T$  ( $i, j = 1, \dots, q, i \neq j$ ) and  $\mathbb{M}_{ijg} = \mathbb{M}_{gji}^T$ ,  $\mathbb{N}_{ijg} = \mathbb{N}_{gji}^T$  ( $i = 1, \dots, q-2, j = i+1, \dots, q-1, g = j+1, \dots, q$ ) such that the following conditions hold:

$$\Phi_{ii} \leq \mathbb{M}_{iii}, \quad i = 1, \dots, q, \quad (31)$$

$$\begin{aligned} \Phi_{ii} + \Phi_{ij} + \Phi_{ji} &\leq \mathbb{M}_{ijj} + \mathbb{M}_{iji} + \mathbb{M}_{ijj}^T, \\ i, j &= 1, \dots, q, \quad i \neq j, \end{aligned} \quad (32)$$

$$\begin{aligned} \Phi_{ij} + \Phi_{ji} + \Phi_{ig} + \Phi_{gi} + \Phi_{jg} + \Phi_{gj} &\leq \mathbb{M}_{ijg} + \mathbb{M}_{igj} + \mathbb{M}_{jig} + \mathbb{M}_{gij}^T + \mathbb{M}_{ijg}^T + \mathbb{M}_{jig}^T, \\ i &= 1, \dots, q-2, \quad j = i+1, \dots, q-1, \\ g &= j+1, \dots, q, \end{aligned} \quad (33)$$

$$\begin{bmatrix} \mathbb{M}_{1i1} & \mathbb{M}_{1i2} & \cdots & \mathbb{M}_{1iq} \\ \mathbb{M}_{2i1} & \mathbb{M}_{2i2} & \cdots & \mathbb{M}_{2iq} \\ \vdots & \vdots & \ddots & \vdots \\ \mathbb{M}_{qi1} & \mathbb{M}_{qi2} & \cdots & \mathbb{M}_{qiq} \end{bmatrix} \leq 0, \quad i = 1, \dots, q, \quad (34)$$

$$\Psi_{ii} \leq \mathbb{N}_{iii}, \quad i = 1, \dots, q, \quad (35)$$

$$\begin{aligned} \Psi_{ii} + \Psi_{ij} + \Psi_{ji} &\leq \mathbb{N}_{ijj} + \mathbb{N}_{iji} + \mathbb{N}_{ijj}^T, \\ i, j &= 1, \dots, q, \quad i \neq j, \end{aligned} \quad (36)$$

$$\begin{aligned} \Psi_{ij} + \Psi_{ji} + \Psi_{ig} + \Psi_{gi} + \Psi_{jg} + \Psi_{gj} &\leq \mathbb{N}_{ijg} + \mathbb{N}_{igj} + \mathbb{N}_{jig} + \mathbb{N}_{gij}^T + \mathbb{N}_{ijg}^T + \mathbb{N}_{jig}^T, \\ i &= 1, \dots, q-2, \quad j = i+1, \dots, q-1, \\ g &= j+1, \dots, q, \end{aligned} \quad (37)$$

$$\begin{bmatrix} \mathbb{N}_{1i1} & \mathbb{N}_{1i2} & \cdots & \mathbb{N}_{1iq} \\ \mathbb{N}_{2i1} & \mathbb{N}_{2i2} & \cdots & \mathbb{N}_{2iq} \\ \vdots & \vdots & \ddots & \vdots \\ \mathbb{N}_{qi1} & \mathbb{N}_{qi2} & \cdots & \mathbb{N}_{qiq} \end{bmatrix} \leq 0, \quad i = 1, \dots, q, \quad (38)$$

where

$$\begin{aligned} \Phi_{ij} &= \begin{bmatrix} -\bar{P} & \bar{P}\bar{A}_{11i} - \bar{Y}_j\bar{A}_{21i} & \bar{Y}_j\bar{D}_{2i} - \bar{P}\bar{D}_{1i} & 0 \\ * & -\bar{P} & 0 & \bar{I}_m \\ * & * & -\gamma_1 I_{(d+m)} & 0 \\ * & * & * & -\gamma_1 I_m \end{bmatrix}, \\ \Psi_{ij} &= \begin{bmatrix} -\bar{P} & \bar{P}\bar{A}_{11i} - \bar{Y}_j\bar{A}_{21i} - \alpha_1 \bar{P} \\ * & -\tau_1^2 \bar{P} \end{bmatrix}, \\ \bar{I}_m &= \begin{bmatrix} 0_{(n-p) \times m} \\ I_m \end{bmatrix}, \end{aligned}$$

then the RFEO (24)–(26) results in the  $H_\infty$  performance index  $\|e_f(k)\|_2 \leq \gamma_1 \|\nu(k)\|_2$  and the eigenvalues of  $(\bar{A}_{11}(h) - \bar{G}(h)\bar{A}_{21}(h))$  belong to  $\mathcal{D}(\alpha_1, \tau_1)$ , and the RFEO gain matrices are given by  $\bar{G}_i = \bar{P}^{-1}\bar{Y}_i$ .

**Proof.** We start with the proof of (31)–(34), and (35)–(38) will be considered subsequently.

Constraints (31)–(34): Consider the following Lyapunov function:

$$V(k) = \bar{e}^T(k)\bar{P}\bar{e}(k). \quad (39)$$

Its difference  $\Delta V(k) = V(k+1) - V(k)$  along the error dynamics (30) is

$$\begin{aligned} \Delta V(k) &= V(k+1) - V(k) \\ &= \bar{e}^T(k+1)\bar{P}\bar{e}(k+1) - \bar{e}^T(k)\bar{P}\bar{e}(k) \\ &= \bar{e}^T(k)(\bar{A}_{11}(h) - \bar{G}(h)\bar{A}_{21}(h))^T \bar{P} \times \\ &\quad (\bar{A}_{11}(h) - \bar{G}(h)\bar{A}_{21}(h))\bar{e}(k) + \\ &\quad 2\bar{e}^T(k)(\bar{A}_{11}(h) - \bar{G}(h)\bar{A}_{21}(h))^T \bar{P} \times \\ &\quad (\bar{G}(h)\bar{D}_2(h) - \bar{D}_1(h))\nu(k) + \\ &\quad \nu^T(k)(\bar{G}(h)\bar{D}_2(h) - \bar{D}_1(h))^T \bar{P} \times \\ &\quad (\bar{G}(h)\bar{D}_2(h) - \bar{D}_1(h))\nu(k) - \bar{e}^T(k)\bar{P}\bar{e}(k). \end{aligned} \quad (40)$$

Now, let us define

$$J_1 = \sum_{k=0}^{N-1} \left[ \frac{1}{\gamma_1} e_f^T(k) e_f(k) - \gamma_1 \nu^T(k) \nu(k) \right]. \quad (41)$$

Under zero initial condition, we get

$$\begin{aligned} J_1 &\leq \sum_{k=0}^{N-1} \left[ \Delta V(k) + \frac{1}{\gamma_1} e_f^T(k) e_f(k) - \gamma_1 \nu^T(k) \nu(k) \right] \\ &= \sum_{k=0}^{N-1} \left[ \Delta V(k) + \frac{1}{\gamma_1} \bar{e}^T(k) \bar{I}_m \bar{I}_m^T \bar{e}(k) - \gamma_1 \nu^T(k) \nu(k) \right]. \end{aligned} \quad (42)$$

It follows from (40) and (42) that

$$\begin{aligned}
& \Delta V(k) + \frac{1}{\gamma_1} \bar{e}^T(k) \bar{I}_m \bar{I}_m^T \bar{e}(k) - \gamma_1 \nu^T(k) \nu(k) \\
&= \bar{e}^T(k) (\bar{A}_{11}(h) - \bar{G}(h) \bar{A}_{21}(h))^T \bar{P} \times \\
& \quad (\bar{A}_{11}(h) - \bar{G}(h) \bar{A}_{21}(h)) \bar{e}(k) + \\
& \quad 2 \bar{e}^T(k) (\bar{A}_{11}(h) - \bar{G}(h) \bar{A}_{21}(h))^T \bar{P} \times \\
& \quad (\bar{G}(h) \bar{D}_2(h) - \bar{D}_1(h)) \nu(k) + \\
& \quad \nu^T(k) (\bar{G}(h) \bar{D}_2(h) - \bar{D}_1(h))^T \bar{P} \times \\
& \quad (\bar{G}(h) \bar{D}_2(h) - \bar{D}_1(h)) \nu(k) - \bar{e}^T(k) \bar{P} \bar{e}(k) + \\
& \quad \frac{1}{\gamma_1} \bar{e}^T(k) \bar{I}_m \bar{I}_m^T \bar{e}(k) - \gamma_1 \nu^T(k) \nu(k) \\
&= \zeta^T(k) \Omega(h, h) \zeta(k), \tag{43}
\end{aligned}$$

where

$$\begin{aligned}
\zeta(k) &= \begin{bmatrix} \bar{e}(k) \\ \nu(k) \end{bmatrix}, \quad \Omega(h, h) = \\
& \begin{bmatrix} (\bar{A}_{11}(h) - \bar{G}(h) \bar{A}_{21}(h))^T \bar{P} (\bar{A}_{11}(h) - \bar{G}(h) \bar{A}_{21}(h)) - \\ \quad \bar{P} + \frac{1}{\gamma_1} \bar{I}_m \bar{I}_m^T \\ * \\ (\bar{A}_{11}(h) - \bar{G}(h) \bar{A}_{21}(h))^T \bar{P} (\bar{G}(h) \bar{D}_2(h) - \bar{D}_1(h)) \\ (\bar{G}(h) \bar{D}_2(h) - \bar{D}_1(h))^T \bar{P} (\bar{G}(h) \bar{D}_2(h) - \bar{D}_1(h)) - \\ \quad \gamma_1 I_{(d+m)} \end{bmatrix}.
\end{aligned}$$

Using the Schur complement,  $\Omega(h, h) \leq 0$  is equivalent to

$$\begin{aligned}
& \begin{bmatrix} (\bar{A}_{11}(h) - \bar{G}(h) \bar{A}_{21}(h))^T \bar{P} (\bar{A}_{11}(h) - \bar{G}(h) \bar{A}_{21}(h)) - \bar{P} \\ * \\ * \\ (\bar{A}_{11}(h) - \bar{G}(h) \bar{A}_{21}(h))^T \bar{P} (\bar{G}(h) \bar{D}_2(h) - \bar{D}_1(h)) \\ (\bar{G}(h) \bar{D}_2(h) - \bar{D}_1(h))^T \bar{P} (\bar{G}(h) \bar{D}_2(h) - \bar{D}_1(h)) - \\ \quad \gamma_1 I_{(d+m)} \\ * \\ \bar{I}_m \\ 0 \\ -\gamma_1 I_m \end{bmatrix} \leq 0. \tag{44}
\end{aligned}$$

Using the Schur complement again, we obtain

$$\begin{aligned}
\Phi(h, h) &:= \begin{bmatrix} -\bar{P} & \bar{P}(\bar{A}_{11}(h) - \bar{G}(h) \bar{A}_{21}(h)) \\ * & -\bar{P} \\ * & * \\ * & * \\ \bar{P}(\bar{G}(h) \bar{D}_2(h) - \bar{D}_1(h)) & 0 \\ 0 & \bar{I}_m \\ -\gamma_1 I_{(d+m)} & 0 \\ * & -\gamma_1 I_m \end{bmatrix} \leq 0, \tag{45}
\end{aligned}$$

which can be rewritten as

$$\begin{aligned}
\Phi(h, h) &= \sum_{i=1}^q \sum_{j=1}^q h_i h_j \Phi_{ij} = \left( \sum_{i=1}^q h_i \right) \sum_{i=1}^q \sum_{j=1}^q h_i h_j \Phi_{ij} \\
&= \sum_{i=1}^q h_i^3 \Phi_{ii} + \sum_{i=1}^q \sum_{\substack{j=1 \\ j \neq i}}^q h_i^2 h_j (\Phi_{ii} + \Phi_{ij} + \Phi_{ji}) +
\end{aligned}$$

$$\begin{aligned}
& \sum_{i=1}^{q-2} \sum_{j=i+1}^{q-1} \sum_{g=j+1}^q h_i h_j h_g (\Phi_{ij} + \Phi_{ji} + \Phi_{ig} + \\
& \quad \Phi_{gi} + \Phi_{jg} + \Phi_{gj}) \tag{46}
\end{aligned}$$

If conditions (31)–(33) hold, one obtains

$$\begin{aligned}
\Phi(h, h) &\leq \sum_{i=1}^q h_i^3 \mathbb{M}_{iii} + \sum_{i=1}^q \sum_{\substack{j=1 \\ j \neq i}}^q h_i^2 h_j (\mathbb{M}_{iij} + \mathbb{M}_{iji} + \mathbb{M}_{iij}^T) + \\
& \quad \sum_{i=1}^{q-2} \sum_{j=i+1}^{q-1} \sum_{g=j+1}^q h_i h_j h_g (\mathbb{M}_{ijg} + \mathbb{M}_{igj} + \mathbb{M}_{jig} + \\
& \quad \mathbb{M}_{ijg}^T + \mathbb{M}_{igj}^T + \mathbb{M}_{jig}^T) \\
&= h_1 \begin{bmatrix} h_1 I \\ h_2 I \\ \vdots \\ h_q I \end{bmatrix}^T \begin{bmatrix} \mathbb{M}_{111} & \mathbb{M}_{112} & \cdots & \mathbb{M}_{11q} \\ \mathbb{M}_{211} & \mathbb{M}_{212} & \cdots & \mathbb{M}_{21q} \\ \vdots & \vdots & \ddots & \vdots \\ \mathbb{M}_{q11} & \mathbb{M}_{q12} & \cdots & \mathbb{M}_{q1q} \end{bmatrix} \times \\
& \quad \begin{bmatrix} h_1 I \\ h_2 I \\ \vdots \\ h_q I \end{bmatrix} + h_2 \begin{bmatrix} h_1 I \\ h_2 I \\ \vdots \\ h_q I \end{bmatrix}^T \times \\
& \quad \begin{bmatrix} \mathbb{M}_{121} & \mathbb{M}_{122} & \cdots & \mathbb{M}_{12q} \\ \mathbb{M}_{221} & \mathbb{M}_{222} & \cdots & \mathbb{M}_{22q} \\ \vdots & \vdots & \ddots & \vdots \\ \mathbb{M}_{q21} & \mathbb{M}_{q22} & \cdots & \mathbb{M}_{q2q} \end{bmatrix} \begin{bmatrix} h_1 I \\ h_2 I \\ \vdots \\ h_q I \end{bmatrix} \\
& \quad + \cdots + h_q \begin{bmatrix} h_1 I \\ h_2 I \\ \vdots \\ h_q I \end{bmatrix}^T \times \\
& \quad \begin{bmatrix} \mathbb{M}_{1q1} & \mathbb{M}_{1q2} & \cdots & \mathbb{M}_{1qq} \\ \mathbb{M}_{2q1} & \mathbb{M}_{2q2} & \cdots & \mathbb{M}_{2qq} \\ \vdots & \vdots & \ddots & \vdots \\ \mathbb{M}_{qq1} & \mathbb{M}_{qq2} & \cdots & \mathbb{M}_{qqq} \end{bmatrix} \begin{bmatrix} h_1 I \\ h_2 I \\ \vdots \\ h_q I \end{bmatrix} \\
&= \begin{bmatrix} h_1 I \\ h_2 I \\ \vdots \\ h_q I \end{bmatrix}^T \times \\
& \quad \left( \sum_{i=1}^q h_i \begin{bmatrix} \mathbb{M}_{1i1} & \mathbb{M}_{1i2} & \cdots & \mathbb{M}_{1iq} \\ \mathbb{M}_{2i1} & \mathbb{M}_{2i2} & \cdots & \mathbb{M}_{2iq} \\ \vdots & \vdots & \ddots & \vdots \\ \mathbb{M}_{qi1} & \mathbb{M}_{qi2} & \cdots & \mathbb{M}_{qiq} \end{bmatrix} \right) \begin{bmatrix} h_1 I \\ h_2 I \\ \vdots \\ h_q I \end{bmatrix} \tag{47}
\end{aligned}$$

It follows that the error dynamics (30) is robustly stable with an  $H_\infty$  performance index  $\|e_f(k)\|_2 \leq \gamma_1 \|\nu(k)\|_2$  provided (34) holds true.

Constraints (35)–(38): Not considering  $\nu(k)$ , and setting  $(\bar{A}_{11}(h) - \bar{G}(h) \bar{A}_{21}(h)) \rightarrow \mathcal{A}$  and  $\bar{P} \rightarrow \mathcal{P}$  in Lemma 1, one gets

$$\Psi(h, h) :=$$



$$\begin{bmatrix} -\bar{P} & \bar{P}(\bar{A}_{11}(h) - \bar{G}(h)\bar{A}_{21}(h)) - \alpha_1\bar{P} \\ * & -\tau_1^2\bar{P} \end{bmatrix} \leq 0, \quad (48)$$

which can be rewritten as

$$\Psi(h, h) = \sum_{i=1}^q \sum_{j=1}^q h_i h_j \Psi_{ij}. \quad (49)$$

Then it follows from the proof of (31)–(34) that if (35)–(38) hold, then the eigenvalues of  $(\bar{A}_{11}(h) - \bar{G}(h)\bar{A}_{21}(h))$  belong to  $\mathcal{D}(\alpha_1, \tau_1)$ .  $\square$

**Remark 3.** Note that the FE filter problem for discrete-time systems proposed in [24], [27] was only suitable for open-loop stable systems. While, achieving the estimation of actuator faults by the system decomposition proposed in [28], [29], would require the constraints  $\text{rank}(C_i B_i)$  are of full-column rank, to be satisfied. From (30), a necessary condition for the proposed fuzzy RFEO design is that the pairs  $(\bar{A}_{11i}, \bar{A}_{21i})$  are observable. Our approach allows to deal with systems that do not satisfy these conditions, an example of which will be given in Section 5.

**Remark 4.** In Theorem 1, the purpose of introducing the regional pole constraint (35)–(38) is to guarantee system stability and control the FE transient performance. Note that other pole placement constraints, such as  $\alpha$ -stability, vertical strips, sectors and the intersection thereof can also be considered [35], [36].

**Remark 5.** Under the given regional pole constraint, the minimum  $H_\infty$  attenuation level of Theorem 1 can be obtained by solving the following semidefinite programming problem [37]:

$$\text{minimize } \gamma_1 \text{ subject to (31) – (38).}$$

This remark also applies to the other  $H_\infty$  performance calculations in this paper.

**Remark 6.** From the RFEO design (24)–(26), the on-line fault estimate is obtained via the following augmented system:

$$\begin{aligned} \begin{bmatrix} \hat{z}_1(k+1) \\ \hat{f}(k+1) \end{bmatrix} &= \begin{bmatrix} A_{11}(h) & B_1(h) \\ 0_{m \times (n-p)} & I_m \end{bmatrix} \begin{bmatrix} \hat{z}_1(k) \\ \hat{f}(k) \end{bmatrix} - \\ &\quad \begin{bmatrix} G(h) \\ F(h) \end{bmatrix} (\hat{\rho}(k) - \rho(k)) + \\ &\quad \begin{bmatrix} I_{n-p} \\ 0_{m \times (n-p)} \end{bmatrix} \eta(k) \\ &= \left( \begin{bmatrix} A_{11}(h) & B_1(h) \\ 0_{m \times (n-p)} & I_m \end{bmatrix} - \right. \\ &\quad \left. \begin{bmatrix} G(h) \\ F(h) \end{bmatrix} \begin{bmatrix} A_{21}(h) & B_2(h) \end{bmatrix} \right) \begin{bmatrix} \hat{z}_1(k) \\ \hat{f}(k) \end{bmatrix} + \\ &\quad \begin{bmatrix} G(h) \\ F(h) \end{bmatrix} \rho(k) + \begin{bmatrix} I_{n-p} \\ 0_{m \times (n-p)} \end{bmatrix} \eta(k) \\ &= (\bar{A}_{11}(h) - \bar{G}(h)\bar{A}_{21}(h)) \begin{bmatrix} \hat{z}_1(k) \\ \hat{f}(k) \end{bmatrix} + \\ &\quad \bar{G}(h)\rho(k) + \bar{I}_{n-p}\eta(k), \end{aligned} \quad (50)$$

where  $\bar{I}_{n-p} = \begin{bmatrix} I_{n-p} \\ 0_{m \times (n-p)} \end{bmatrix}$ . Then substituting the vectors

$\eta(k)$  and  $\rho(k)$  into (50), one obtains

$$\begin{aligned} \begin{bmatrix} \hat{z}_1(k+1) \\ \hat{f}(k+1) \end{bmatrix} &= (\bar{A}_{11}(h) - \bar{G}(h)\bar{A}_{21}(h)) \begin{bmatrix} \hat{z}_1(k) \\ \hat{f}(k) \end{bmatrix} + \\ &\quad \bar{G}(h)y(k+1) + \\ &\quad (\bar{I}_{n-p}A_{12}(h) - \bar{G}(h)A_{22}(h))y(k) + \\ &\quad (\bar{I}_{n-p}B_1(h) - \bar{G}(h)B_2(h))u(k). \end{aligned} \quad (51)$$

In fact, the advantage of the fault estimator (51) lies in using the current output information to achieve FE. To show this point clear, we introduce a new variable  $\chi(k+1) = \begin{bmatrix} \hat{z}_1(k+1) \\ \hat{f}(k+1) \end{bmatrix} - \bar{G}(h)y(k+1)$ , and one gets

$$\chi(k) = \begin{bmatrix} \hat{z}_1(k) \\ \hat{f}(k) \end{bmatrix} - \bar{G}(h_-)y(k),$$

where  $\bar{G}(h_-)$  is the value at time  $k-1$ . Then it follows from (51) that

$$\begin{aligned} \chi(k+1) &= (\bar{A}_{11}(h) - \bar{G}(h)\bar{A}_{21}(h))(\chi(k) + \bar{G}(h_-)y(k)) \\ &\quad + (\bar{I}_{n-p}A_{12}(h) - \bar{G}(h)A_{22}(h))y(k) + \\ &\quad (\bar{I}_{n-p}B_1(h) - \bar{G}(h)B_2(h))u(k) \\ &= (\bar{A}_{11}(h) - \bar{G}(h)\bar{A}_{21}(h))\chi(k) + \\ &\quad \left( (\bar{A}_{11}(h) - \bar{G}(h)\bar{A}_{21}(h))\bar{G}(h_-) + \right. \\ &\quad \left. (\bar{I}_{n-p}A_{12}(h) - \bar{G}(h)A_{22}(h)) \right)y(k) + \\ &\quad (\bar{I}_{n-p}B_1(h) - \bar{G}(h)B_2(h))u(k). \end{aligned} \quad (52)$$

Further, it follows that

$$\begin{bmatrix} \hat{z}_1(k) \\ \hat{f}(k) \end{bmatrix} = \chi(k) + \bar{G}(h_-)y(k), \quad (53)$$

and finally, the on-line fault estimate is given by

$$\hat{f}(k) = \bar{I}_m^T \begin{bmatrix} \hat{z}_1(k) \\ \hat{f}(k) \end{bmatrix}, \quad (54)$$

which readily shows that the fault estimator contains the current output information, and allows to enhance the FE performance.

If we use a single RFEO gain matrix to deal with all fuzzy subsystems, i.e.  $\bar{G} := \bar{G}_1 = \bar{G}_2 = \dots = \bar{G}_q$ , then it results in the following Corollary 1, which can be treated as a special case of Theorem 1.

**Corollary 1.** Let a prescribed  $H_\infty$  performance level  $\gamma_1$  and a circular region  $\mathcal{D}(\alpha_1, \tau_1)$  be given. If there exists a symmetric positive definite matrix  $\bar{P} \in \mathbb{R}^{(n+m-p) \times (n+m-p)}$  and a matrix  $\bar{Y} \in \mathbb{R}^{(n+m-p) \times p}$  such that the following conditions hold:

$$\Lambda_i \leq 0, \quad i = 1, \dots, q, \quad (55)$$

$$\Delta_i \leq 0, \quad i = 1, \dots, q, \quad (56)$$

where

$$\Lambda_i = \begin{bmatrix} -\bar{P} & \bar{P}\bar{A}_{11i} - \bar{Y}\bar{A}_{21i} & \bar{Y}\bar{D}_{2i} - \bar{P}\bar{D}_{1i} & 0 \\ * & -\bar{P} & 0 & \bar{I}_m \\ * & * & -\gamma_1 I_{(d+m)} & 0 \\ * & * & * & -\gamma_1 I_m \end{bmatrix},$$

$$\Delta_i = \begin{bmatrix} -\bar{P} & \bar{P}\bar{A}_{11i} - \bar{Y}\bar{A}_{21i} - \alpha_1\bar{P} \\ * & -\tau_1^2\bar{P} \end{bmatrix},$$

$$\bar{I}_m = \begin{bmatrix} 0_{(n-p) \times m} \\ I_m \end{bmatrix},$$

then the RFEO (24)–(26) results in the  $H_\infty$  performance index  $\|e_f(k)\|_2 \leq \gamma_1 \|\nu(k)\|_2$  and the eigenvalues of  $(\bar{A}_{11}(h) - \bar{G}\bar{A}_{21}(h))$  belong to  $\mathcal{D}(\alpha_1, \tau_1)$ , and the RFEO gain matrix is given by  $\bar{G} = \bar{P}^{-1}\bar{Y}$ .

Therefore, using Corollary 1, (52) becomes

$$\begin{aligned} \chi(k+1) &= (\bar{A}_{11}(h) - \bar{G}\bar{A}_{21}(h))(\chi(k) + \bar{G}y(k)) + \\ &\quad (\bar{I}_{n-p}A_{12}(h) - \bar{G}A_{22}(h))y(k) + \\ &\quad (\bar{I}_{n-p}B_1(h) - \bar{G}B_2(h))u(k) \\ &= (\bar{A}_{11}(h) - \bar{G}\bar{A}_{21}(h))\chi(k) + \\ &\quad ((\bar{A}_{11}(h) - \bar{G}\bar{A}_{21}(h))\bar{G} + \\ &\quad (\bar{I}_{n-p}A_{12}(h) - \bar{G}A_{22}(h)))y(k) + \\ &\quad (\bar{I}_{n-p}B_1(h) - \bar{G}B_2(h))u(k). \end{aligned} \quad (57)$$

Finally, the on-line fault estimate is given by

$$\hat{f}(k) = \bar{I}_m^T \begin{bmatrix} \hat{z}_1(k) \\ \hat{f}(k) \end{bmatrix} = \bar{I}_m^T (\chi(k) + \bar{G}y(k)). \quad (58)$$

#### IV. FAULT ACCOMMODATION DESIGN

On the basis of the obtained on-line FE information, we design a fault tolerant controller to guarantee stability in the presence of faults. Since the state  $x(k)$  is unmeasurable, we use the fuzzy dynamical output feedback controller scheme [15], [38] to construct the fuzzy DOFFTC for T-S fuzzy models as

$$\xi(k+1) = A_K(h, h)\xi(k) + B_K(h)y(k), \quad (59)$$

$$u(k) = C_K(h)\xi(k) + D_K y(k) - \hat{f}(k), \quad (60)$$

where  $\xi(k) \in \mathbb{R}^n$  is the state,  $A_K(h, h) \in \mathbb{R}^{n \times n}$ ,  $B_K(h) \in \mathbb{R}^{n \times p}$ ,  $C_K(h) \in \mathbb{R}^{m \times n}$  and  $D_K \in \mathbb{R}^{m \times p}$  are the designed DOFFTC matrices, and

$$A_K(h, h) = \sum_{i=1}^q \sum_{j=1}^q h_i h_j A_{Kij}, \quad B_K(h) = \sum_{i=1}^q h_i B_{Ki},$$

$$C_K(h) = \sum_{i=1}^q h_i C_{Ki}.$$

Substituting (13) into (59) and (60), one obtains

$$\xi(k+1) = A_K(h, h)\xi(k) + B_K(h)Cx(k), \quad (61)$$

$$u(k) = C_K(h)\xi(k) + D_K Cx(k) - \hat{f}(k). \quad (62)$$

Then substituting  $u(k)$  into (12), we further obtain

$$\begin{aligned} x(k+1) &= A(h)x(k) + B(h)C_K(h)\xi(k) + \\ &\quad B(h)D_K Cx(k) - B(h)\hat{f}(k) + \\ &\quad B(h)f(k) + D(h)\omega(k) \\ &= A(h)x(k) + B(h)C_K(h)\xi(k) + \\ &\quad B(h)D_K Cx(k) - B(h)e_f(k) + D(h)\omega(k) \end{aligned}$$

$$\begin{aligned} &= (A(h) + B(h)D_K C)x(k) + B(h)C_K(h)\xi(k) \\ &\quad + D(h)\omega(k) - B(h)e_f(k). \end{aligned} \quad (63)$$

It follows that

$$\tilde{x}(k+1) = \tilde{A}(h, h)\tilde{x}(k) + \tilde{D}(h)\mu(k), \quad (64)$$

$$z_L(k) = \tilde{C}_L(h)\tilde{x}(k), \quad (65)$$

where

$$\begin{aligned} \tilde{x}(k) &= \begin{bmatrix} x(k) \\ \xi(k) \end{bmatrix}, \quad \mu(k) = \begin{bmatrix} \omega(k) \\ e_f(k) \end{bmatrix}, \\ \tilde{A}(h, h) &= \begin{bmatrix} A(h) + B(h)D_K C & B(h)C_K(h) \\ B_K(h)C & A_K(h, h) \end{bmatrix}, \\ \tilde{D}(h) &= \begin{bmatrix} D(h) & -B(h) \\ 0_{n \times d} & 0_{n \times m} \end{bmatrix}, \quad \tilde{C}_L(h) = [C_L(h) \quad 0_{l \times n}]. \end{aligned}$$

Theorem 2 gives a FA design based on dynamic output feedback control, in which FA performances are specified by an  $H_\infty$  performance index and a regional pole constraint.

**Theorem 2.** Let a prescribed  $H_\infty$  performance level  $\gamma_2$  and a circular region  $\mathcal{D}(\alpha_2, \tau_2)$  be given. If there exist two symmetric positive definite matrices  $X, Y \in \mathbb{R}^{n \times n}$ ; matrices  $\hat{A}_{ij} \in \mathbb{R}^{n \times n}$ ,  $\hat{B}_i \in \mathbb{R}^{n \times p}$ ,  $\hat{C}_i \in \mathbb{R}^{m \times n}$ ,  $\hat{D} \in \mathbb{R}^{m \times p}$  ( $i, j = 1, \dots, q$ ); matrices with appropriate dimensions  $\mathbb{U}_{iii}, \mathbb{V}_{iii}$  ( $i = 1, \dots, q$ );  $\mathbb{U}_{jii} = \mathbb{U}_{ijj}^T$ ,  $\mathbb{U}_{iji}$ ,  $\mathbb{V}_{jii} = \mathbb{V}_{ijj}^T$ ,  $\mathbb{V}_{iji}$  ( $i, j = 1, \dots, q, i \neq j$ ) and  $\mathbb{U}_{ijg} = \mathbb{U}_{gji}^T$ ,  $\mathbb{U}_{igj} = \mathbb{U}_{jgi}^T$ ,  $\mathbb{U}_{jig} = \mathbb{U}_{gij}^T$ ,  $\mathbb{V}_{ijg} = \mathbb{V}_{gji}^T$ ,  $\mathbb{V}_{igj} = \mathbb{V}_{jgi}^T$ ,  $\mathbb{V}_{jig} = \mathbb{V}_{gij}^T$  ( $i = 1, \dots, q-2, j = i+1, \dots, q-1, g = j+1, \dots, q$ ) such that the following conditions hold:

$$\Xi_{ii} \leq \mathbb{U}_{iii}, \quad i = 1, \dots, q, \quad (66)$$

$$\begin{aligned} \Xi_{ii} + \Xi_{ij} + \Xi_{ji} &\leq \mathbb{U}_{ijj} + \mathbb{U}_{iji} + \mathbb{U}_{ijj}^T, \\ i, j &= 1, \dots, q, i \neq j, \end{aligned} \quad (67)$$

$$\begin{aligned} \Xi_{ij} + \Xi_{ji} + \Xi_{ig} + \Xi_{gi} + \Xi_{jg} + \Xi_{gj} &\leq \mathbb{U}_{ijg} + \\ &\quad \mathbb{U}_{igj} + \mathbb{U}_{jig} + \mathbb{U}_{ijg}^T + \mathbb{U}_{igj}^T + \mathbb{U}_{jig}^T, \\ i &= 1, \dots, q-2, j = i+1, \dots, q-1, \\ g &= j+1, \dots, q, \end{aligned} \quad (68)$$

$$\begin{bmatrix} \mathbb{U}_{1i1} & \mathbb{U}_{1i2} & \cdots & \mathbb{U}_{1iq} \\ \mathbb{U}_{2i1} & \mathbb{U}_{2i2} & \cdots & \mathbb{U}_{2iq} \\ \vdots & \vdots & \ddots & \vdots \\ \mathbb{U}_{qi1} & \mathbb{U}_{qi2} & \cdots & \mathbb{U}_{qiq} \end{bmatrix} \leq 0, \quad i = 1, \dots, q, \quad (69)$$

$$\Pi_{ii} \leq \mathbb{V}_{iii}, \quad i = 1, \dots, q, \quad (70)$$

$$\begin{aligned} \Pi_{ii} + \Pi_{ij} + \Pi_{ji} &\leq \mathbb{V}_{ijj} + \mathbb{V}_{iji} + \mathbb{V}_{ijj}^T, \\ i, j &= 1, \dots, q, i \neq j, \end{aligned} \quad (71)$$

$$\begin{aligned} \Pi_{ij} + \Pi_{ji} + \Pi_{ig} + \Pi_{gi} + \Pi_{jg} + \Pi_{gj} &\leq \mathbb{V}_{ijg} + \\ &\quad \mathbb{V}_{igj} + \mathbb{V}_{jig} + \mathbb{V}_{ijg}^T + \mathbb{V}_{igj}^T + \mathbb{V}_{jig}^T, \\ i &= 1, \dots, q-2, j = i+1, \dots, q-1, \\ g &= j+1, \dots, q, \end{aligned} \quad (72)$$

$$\begin{bmatrix} \mathbb{V}_{1i1} & \mathbb{V}_{1i2} & \cdots & \mathbb{V}_{1iq} \\ \mathbb{V}_{2i1} & \mathbb{V}_{2i2} & \cdots & \mathbb{V}_{2iq} \\ \vdots & \vdots & \ddots & \vdots \\ \mathbb{V}_{qi1} & \mathbb{V}_{qi2} & \cdots & \mathbb{V}_{qiq} \end{bmatrix} \leq 0, \quad i = 1, \dots, q, \quad (73)$$



where

$$\Xi_{ij} = \begin{bmatrix} -X & -I_n & A_i X + B_i \hat{C}_j & A_i + B_i \hat{D} C \\ * & -Y & \hat{A}_{ij} & Y A_i + \hat{B}_j C \\ * & * & -X & -I_n \\ * & * & * & -Y \\ * & * & * & * \\ * & * & * & * \\ * & * & * & * \end{bmatrix},$$

$$\Pi_{ij} = \begin{bmatrix} D_i & -B_i & 0 \\ Y D_i & -Y B_i & 0 \\ 0 & 0 & X C_{Li}^T \\ 0 & 0 & C_{Li}^T \\ -\gamma_2 I_d & 0 & 0 \\ * & -\gamma_2 I_m & 0 \\ * & * & -\gamma_2 I_l \end{bmatrix},$$

$$\Pi_{ij} = \begin{bmatrix} -X & -I_n & A_i X + B_i \hat{C}_j - \alpha_2 X \\ * & -Y & \hat{A}_{ij} - \alpha_2 I_n \\ * & * & -\tau_2^2 X \\ * & * & * \end{bmatrix},$$

$$\begin{bmatrix} A_i + B_i \hat{D} C - \alpha_2 I_n \\ Y A_i + \hat{B}_j C - \alpha_2 Y \\ -\tau_2^2 I_n \\ -\tau_2^2 Y \end{bmatrix},$$

then the system dynamics (64) and (65) satisfy the  $H_\infty$  performance index  $\|z_L(k)\|_2 \leq \gamma_2 \|\mu(k)\|_2$  and the eigenvalues of  $\tilde{A}(h, h)$  belong to  $D(\alpha_2, \tau_2)$ , and the parameter matrices of the DOFFTC are given by

$$\begin{aligned} D_K &= \hat{D}, \\ C_{Ki} &= (\hat{C}_i - D_K C X) M^{-T}, \\ B_{Ki} &= N^{-1}(\hat{B}_i - Y B_i D_K), \\ A_{Kij} &= N^{-1}(\hat{A}_{ij} - Y(A_i + B_i D_K C) X) M^{-T} - \\ & B_{Kj} C X M^{-T} - N^{-1} Y B_i C_{Kj}, \end{aligned}$$

where  $M, N \in \mathbb{R}^{n \times n}$  satisfy  $MN^T = I_n - XY$ .

**Proof.** We start with the proof of (66)–(69), and (70)–(73) will be considered subsequently.

Constraints (66)–(69): Consider the following Lyapunov function

$$V(k) = \tilde{x}^T(k) \tilde{P} \tilde{x}(k). \quad (74)$$

Its difference  $\Delta V(k) = V(k+1) - V(k)$  along the error dynamics (64) is

$$\begin{aligned} \Delta V(k) &= \tilde{x}^T(k+1) \tilde{P} \tilde{x}(k+1) - \tilde{x}^T(k) \tilde{P} \tilde{x}(k) \\ &= \tilde{x}^T(k) \tilde{A}^T(h, h) \tilde{P} \tilde{A}(h, h) \tilde{x}(k) + \\ & 2\tilde{x}^T(k) \tilde{A}^T(h, h) \tilde{P} \tilde{D}(h) \mu(k) + \\ & \mu^T(k) \tilde{D}^T(h) \tilde{P} \tilde{D}(h) \mu(k) - \tilde{x}^T(k) \tilde{P} \tilde{x}(k). \end{aligned} \quad (75)$$

Let us introduce

$$J_2 = \sum_{k=0}^{N-1} \left[ \frac{1}{\gamma_2} z_L^T(k) z_L(k) - \gamma_2 \mu^T(k) \mu(k) \right]. \quad (76)$$

It can be shown that

$$J_2 \leq \sum_{k=0}^{N-1} \left[ \Delta V(k) + \frac{1}{\gamma_2} z_L^T(k) z_L(k) - \gamma_2 \mu^T(k) \mu(k) \right]. \quad (77)$$

Substituting (75) into (77), one obtains

$$\begin{aligned} & \Delta V(k) + \frac{1}{\gamma_2} z_L^T(k) z_L(k) - \gamma_2 \mu^T(k) \mu(k) \\ &= \tilde{x}^T(k) \tilde{A}^T(h, h) \tilde{P} \tilde{A}(h, h) \tilde{x}(k) + \\ & 2\tilde{x}^T(k) \tilde{A}^T(h, h) \tilde{P} \tilde{D}(h) \mu(k) + \mu^T(k) \tilde{D}^T(h) \tilde{P} \tilde{D}(h) \mu(k) - \\ & \tilde{x}^T(k) \tilde{P} \tilde{x}(k) + \frac{1}{\gamma_2} z_L^T(k) z_L(k) - \gamma_2 \mu^T(k) \mu(k) \\ &= \tilde{x}^T(k) \tilde{A}^T(h, h) \tilde{P} \tilde{A}(h, h) \tilde{x}(k) + \\ & 2\tilde{x}^T(k) \tilde{A}^T(h, h) \tilde{P} \tilde{D}(h) \mu(k) + \mu^T(k) \tilde{D}^T(h) \tilde{P} \tilde{D}(h) \mu(k) - \\ & \tilde{x}^T(k) \tilde{P} \tilde{x}(k) + \frac{1}{\gamma_2} \tilde{x}^T(k) \tilde{C}_L^T(h) \tilde{C}_L(h) \tilde{x}(k) - \gamma_2 \mu^T(k) \mu(k) \\ &= \varsigma^T(k) \Theta(h, h) \varsigma(k), \end{aligned} \quad (78)$$

where

$$\varsigma(k) = \begin{bmatrix} \tilde{x}(k) \\ \mu(k) \end{bmatrix},$$

$$\Theta(h, h) = \begin{bmatrix} \tilde{A}^T(h, h) \tilde{P} \tilde{A}(h, h) - \tilde{P} + \frac{1}{\gamma_2} \tilde{C}_L^T(h) \tilde{C}_L(h) \\ * \\ \tilde{A}^T(h, h) \tilde{P} \tilde{D}(h) \\ \tilde{D}^T(h) \tilde{P} \tilde{D}(h) - \gamma_2 I_{(d+m)} \end{bmatrix}.$$

Using the Schur complement,  $\Theta(h, h) \leq 0$  is equivalent to

$$\begin{bmatrix} -\tilde{P} & \tilde{P} \tilde{A}(h, h) & \tilde{P} \tilde{D}(h) & 0 \\ * & -\tilde{P} & 0 & \tilde{C}_L^T(h) \\ * & * & -\gamma_2 I_{(d+m)} & 0 \\ * & * & * & -\gamma_2 I_l \end{bmatrix} \leq 0. \quad (79)$$

Then we express the symmetric positive definite matrix  $\tilde{P}$  and its inverse matrix  $\tilde{P}^{-1}$  as

$$\tilde{P} = \begin{bmatrix} Y & N \\ N^T & W \end{bmatrix}, \quad \tilde{P}^{-1} = \begin{bmatrix} X & M \\ M^T & Z \end{bmatrix}.$$

Due to  $\tilde{P} \tilde{P}^{-1} = I_{2n}$ , one gets  $\tilde{P} \begin{bmatrix} X \\ M^T \end{bmatrix} = \begin{bmatrix} I_n \\ 0_n \end{bmatrix}$  and  $\tilde{P} \begin{bmatrix} X & I_n \\ M^T & 0_n \end{bmatrix} = \begin{bmatrix} I_n & Y \\ 0_n & N^T \end{bmatrix}.$

Denote

$$F_1 = \begin{bmatrix} X & I_n \\ M^T & 0_n \end{bmatrix}, \quad F_2 = \begin{bmatrix} I_n & Y \\ 0_n & N^T \end{bmatrix}.$$

then it follows that  $\tilde{P} F_1 = F_2$ . Pre- and post-multiplying by  $\text{diag}(F_1^T, F_1^T, I_{(d+m)}, I_l)$  and its transpose in (79), one gets

$$F_1^T \tilde{P} F_1 = \begin{bmatrix} X & I_n \\ I_n & Y \end{bmatrix},$$

$$\begin{aligned}
F_1^T \tilde{P} \tilde{A}(h, h) F_1 &= \\
&\begin{bmatrix} A(h)X + B(h)(D_K C X + C_K(h)M^T) \\ Y(A(h) + B(h)D_K C)X + NB_K(h)CX + \\ YB(h)C_K(h)M^T + NA_K(h, h)M^T \\ A(h) + B(h)D_K C \\ YA(h) + (YB(h)D_K + NB_K(h))C \end{bmatrix}, \\
F_1^T \tilde{P} \tilde{D}(h) &= \begin{bmatrix} D(h) & -B(h) \\ YD(h) & -YB(h) \end{bmatrix}, \\
F_1^T \tilde{C}_L^T(h) &= \begin{bmatrix} XC_L^T(h) \\ C_L^T(h) \end{bmatrix}.
\end{aligned}$$

Denote

$$\begin{aligned}
\hat{A}(h, h) &= Y(A(h) + B(h)D_K C)X + NB_K(h)CX + \\
&\quad YB(h)C_K(h)M^T + NA_K(h, h)M^T, \\
\hat{B}(h) &= YB(h)D_K + NB_K(h), \\
\hat{C}(h) &= D_K C X + C_K(h)M^T, \\
\hat{D} &= D_K.
\end{aligned}$$

then (79) can be expressed as

$$\begin{aligned}
\Xi(h, h) &:= \begin{bmatrix} -X & -I_n & A(h)X + B(h)\hat{C}(h) \\ * & -Y & \hat{A}(h, h) \\ * & * & -X \\ * & * & * \\ * & * & * \\ * & * & * \\ * & * & * \end{bmatrix} \\
&\quad \begin{bmatrix} A(h) + B(h)\hat{D}C & D(h) & -B(h) & 0 \\ YA(h) + \hat{B}(h)C & YD(h) & -YB(h) & 0 \\ -I_n & 0 & 0 & XC_L^T(h) \\ -Y & 0 & 0 & C_L^T(h) \\ * & -\gamma_2 I_d & 0 & 0 \\ * & * & -\gamma_2 I_m & 0 \\ * & * & * & -\gamma_2 I_l \end{bmatrix} \leq 0,
\end{aligned} \tag{80}$$

Therefore,  $\Xi(h, h) \leq 0$  can be rewritten as

$$\Xi(h, h) = \sum_{i=1}^q \sum_{j=1}^q h_i h_j \Xi_{ij}. \tag{81}$$

Then it follows from the proof of Theorem 1 that if (66)–(69) hold, the system dynamics (64) and (65) are robustly stable with an  $H_\infty$  performance index  $\|z_L(k)\|_2 \leq \gamma_2 \|\mu(k)\|_2$ .

Constraints (70)–(73): Not considering  $\mu(k)$ , and setting  $\tilde{A}(h, h) \rightarrow \mathcal{A}$  and  $\tilde{P} \rightarrow \mathcal{P}$  in Lemma 1, one gets

$$\begin{bmatrix} -\tilde{P} & \tilde{P} \tilde{A}(h, h) - \alpha_2 \tilde{P} \\ * & -\tau_2^2 \tilde{P} \end{bmatrix} \leq 0, \tag{82}$$

Pre- and post-multiplying by  $\text{diag}(F_1^T, F_1^T)$  and its transpose in (82), and then using the definitions  $\hat{A}(h, h)$ ,  $\hat{B}(h)$ ,  $\hat{C}(h)$

and  $\hat{D}$ , one gets

$$\begin{aligned}
\Pi(h, h) &:= \begin{bmatrix} -X & -I_n & A(h)X + B(h)\hat{C}(h) - \alpha_2 X \\ * & -Y & \hat{A}(h, h) - \alpha_2 I_n \\ * & * & -\tau_2^2 X \\ * & * & * \end{bmatrix} \\
&\quad \begin{bmatrix} A(h) + B(h)D_K C - \alpha_2 I_n \\ YA(h) + \hat{B}(h)C - \alpha_2 Y \\ -\tau_2^2 I_n \\ -\tau_2^2 Y \end{bmatrix} \leq 0,
\end{aligned} \tag{83}$$

which can be rewritten as

$$\Pi(h, h) = \sum_{i=1}^q \sum_{j=1}^q h_i h_j \Pi_{ij}. \tag{84}$$

Then it follows from the proof of Theorem 1 that if (70)–(73) hold, then the eigenvalues of  $\tilde{A}(h, h)$  belong to  $\mathcal{D}(\alpha_2, \tau_2)$ .  $\square$

**Remark 7.** From Sections 3 and 4, we can see that the RFEO and the DOFFTC are designed separately and their performances are considered simultaneously, which can avoid design difficulties caused by the coupling between them and is convenient to calculate their respective design parameters.

**Remark 8.** In order to reduce conservatism caused by conventional T-S fuzzy design methods, in this paper, we have adopted relaxed quadratic stabilization results obtained in [39]. Moreover, for possible improved results, i.e. a more general case in terms of necessary and sufficient conditions when a design parameter  $n$  tends to infinity, please refer to [40]. However, the multiconstrained design, i.e. an  $H_\infty$  performance index and a regional pole constraint, is considered in both the RFEO and the DOFFTC, so the conditions of Theorems 1 and 2 are still sufficient even using the method in [40].

**Remark 9.** In this paper, only discrete-time T-S fuzzy systems are considered, please note that the proposed FE and accommodation design method can be readily extended to continuous-time T-S fuzzy ones. For the implementation procedure, interested readers can refer to this work and [7], [8], [16].

## V. SIMULATION RESULTS

**System description.** In this section, a discrete-time nonlinear truck-trailer model borrowed from [41], [42] is considered to illustrate the effectiveness of the proposed method.

$$\begin{aligned}
x_1(k+1) &= \left(1 - \frac{vt}{L}\right) x_1(k) + \frac{vt}{l} u(k) \\
x_2(k+1) &= \frac{vt}{L} x_1(k) + x_2(k) \\
x_3(k+1) &= x_3(k) + vt \sin(\theta(k)) \\
y_1(k) &= x_2(k), \quad y_2(k) = x_3(k) \\
z_L(k) &= 0.05 x_3(k)
\end{aligned}$$

where  $x_1(k)$  is the angle difference between truck and trailer (rad),  $x_2(k)$  is the angle of trailer (rad) and  $x_3(k)$  is the vertical position of rear of trailer (m) and  $u(k)$  is the steering angle (rad).  $l$  is the length of truck,  $L$  is the length of trailer,  $t$  is sampling time and  $v$  is the constant speed of backing up. In all

simulations,  $l = 2.8\text{m}$ ,  $L = 5.5\text{m}$ ,  $t = 2\text{s}$  and  $v = -1.0\text{m/s}$ .  $\theta(k) = (vt/2L)x_1(k) + x_2(k)$ . Since  $x_1(k)$  is unavailable, we use  $\hat{x}_1(k)$  as a substitute for  $x_1(k)$ . The nonlinear system can be modeled as a two-rule fuzzy model.

**Rule 1:** IF  $\theta(k)$  is about 0, THEN

$$\begin{aligned} x(k+1) &= A_1x(k) + B_1u(k), \\ y(k) &= C_1x(k), \\ z_L(k) &= C_{L1}x(k) \end{aligned}$$

**Rule 2:** IF  $\theta(k)$  is about  $\pm\pi$ , THEN

$$\begin{aligned} x(k+1) &= A_2x(k) + B_2u(k), \\ y(k) &= C_2x(k), \\ z_L(k) &= C_{L2}x(k) \end{aligned}$$

where

$$\begin{aligned} A_1 &= \begin{bmatrix} 1 - \frac{vt}{L} & 0 & 0 \\ \frac{vt}{L} & 1 & 0 \\ \frac{(vt)^2}{2L} & vt & 1 \end{bmatrix}, \quad B_1 = \begin{bmatrix} \frac{vt}{l} \\ 0 \\ 0 \end{bmatrix}, \\ A_2 &= \begin{bmatrix} 1 - \frac{vt}{L} & 0 & 0 \\ \frac{vt}{L} & 1 & 0 \\ \frac{0.01(vt)^2}{2L\pi} & \frac{0.01vt}{\pi} & 1 \end{bmatrix}, \quad B_2 = \begin{bmatrix} \frac{vt}{l} \\ 0 \\ 0 \end{bmatrix}, \\ C_1 &= \begin{bmatrix} 0 & 1 & 0 \\ 0 & 0 & 1 \end{bmatrix}, \quad C_2 = \begin{bmatrix} 0 & 1 & 0 \\ 0 & 0 & 1 \end{bmatrix}, \\ C_{L1} &= [0 \quad 0 \quad 0.05], \quad C_{L2} = [0 \quad 0 \quad 0.05]. \end{aligned}$$

The membership functions are

$$h_1 = \frac{\sigma_1}{\sigma_1 + \sigma_2}, \quad h_2 = \frac{\sigma_2}{\sigma_1 + \sigma_2}$$

where

$$\sigma_1 = e^{-5\theta_k^2}, \quad \sigma_2 = \max\{e^{-5(\theta_k - \pi)^2}, e^{-5(\theta_k + \pi)^2}\}.$$

Membership functions for Rules 1 and 2 are shown in Figure 1.




Fig. 1. Membership functions of the two-rule model.

Note that we assume only the last two states to be measured, rather than all states [41], [42], to achieve the actuator faults estimation, thus setting a more restrictive problem. It is assumed that the disturbance distribution matrices are chosen as  $D_1 = D_2 = \begin{bmatrix} 0.1 & 0.1 & 0.1 \end{bmatrix}^T$ . It is easy to verify that the pairs  $(A_i, B_i)$  are controllable and the pairs  $(A_i, C_i)$  are observable. Note that it can be verified that  $\text{rank}(C_i B_i) = 0$ , the FE design in [28], [29] can not be used for this system to achieve FE. Meanwhile, from system matrices  $A_i$ , it is shown that the system is open-loop unstable, so the FE filter design in [24], [27] is also not suitable for such system.

**Fault estimation design.** From the system description, it is shown that  $C_1 = C_2$ , so the state transformation matrix can be chosen as  $T = \begin{bmatrix} 1 & 0 & 0 \\ & C & \end{bmatrix}^{-1} = I_3$ . It follows that the fuzzy RFEO augmented matrices can be constructed as

$$\begin{aligned} \bar{A}_{111} &= \begin{bmatrix} A_{111} & B_{11} \\ 0 & I \end{bmatrix} = \begin{bmatrix} 1.3636 & -0.7143 \\ 0 & 1.0000 \end{bmatrix}, \\ \bar{A}_{112} &= \begin{bmatrix} A_{112} & B_{12} \\ 0 & I \end{bmatrix} = \begin{bmatrix} 1.3636 & -0.7143 \\ 0 & 1.0000 \end{bmatrix}, \\ \bar{A}_{211} &= \begin{bmatrix} A_{211} & B_{21} \end{bmatrix} = \begin{bmatrix} -0.3636 & 0 \\ 0.3636 & 0 \end{bmatrix}, \\ \bar{A}_{212} &= \begin{bmatrix} A_{212} & B_{22} \end{bmatrix} = \begin{bmatrix} -0.3636 & 0 \\ 0.0012 & 0 \end{bmatrix}, \\ \bar{D}_{11} &= \begin{bmatrix} D_{11} & 0 \\ 0 & I \end{bmatrix} = \begin{bmatrix} 0.1000 & 0 \\ 0 & 1.0000 \end{bmatrix}, \\ \bar{D}_{12} &= \begin{bmatrix} D_{12} & 0 \\ 0 & I \end{bmatrix} = \begin{bmatrix} 0.1000 & 0 \\ 0 & 1.0000 \end{bmatrix}, \\ \bar{D}_{21} &= \begin{bmatrix} D_{21} & 0_{2 \times 1} \end{bmatrix} = \begin{bmatrix} 0.1000 & 0 \\ 0.1000 & 0 \end{bmatrix}, \\ \bar{D}_{22} &= \begin{bmatrix} D_{22} & 0_{2 \times 1} \end{bmatrix} = \begin{bmatrix} 0.1000 & 0 \\ 0.1000 & 0 \end{bmatrix}. \end{aligned}$$

It is seen that the pairs  $(\bar{A}_{111}, \bar{A}_{211})$  and  $(\bar{A}_{112}, \bar{A}_{212})$  are observable. Solving the conditions in Theorem 1 with the regional pole constraint  $\mathcal{D}(0.5, 0.45)$  allows to take into account both the estimation convergence speed and the level of disturbance attenuation, then one obtains the optimal value  $\gamma_1 = 2.4020$  with

$$\begin{aligned} \bar{P} &= \begin{bmatrix} 1.9346 & 1.5622 \\ 1.5622 & 1.8103 \end{bmatrix}, \quad \bar{G}_1 = \begin{bmatrix} -0.8687 & 3.7256 \\ 0.7032 & -1.4018 \end{bmatrix}, \\ \bar{G}_2 &= \begin{bmatrix} -4.5824 & 3.7256 \\ 2.1005 & -1.4018 \end{bmatrix}. \end{aligned}$$

**Fault accommodation design.** We set the circle region as  $\mathcal{D}(0, 0.999)$  to obtain a smaller  $H_\infty$  performance index as much as possible. By solving the conditions in Theorem 2, one obtains the minimum attenuation value  $\gamma_2 = 2.0282$  with

$$\begin{aligned} X &= \begin{bmatrix} 27.8504 & 7.0691 & 0.0132 \\ 7.0691 & 2.6140 & 1.2150 \\ 0.0132 & 1.2150 & 2.9169 \end{bmatrix}, \\ Y &= \begin{bmatrix} 2.8289 & 8.8895 & -0.5989 \\ 8.8895 & 43.6326 & -2.6413 \\ -0.5989 & -2.6413 & 2.6398 \end{bmatrix}, \end{aligned}$$

$$\begin{aligned}
M &= \begin{bmatrix} -0.9554 & 0.1769 & 0.2365 \\ -0.2888 & -0.3920 & -0.8734 \\ -0.0618 & -0.9028 & 0.4256 \end{bmatrix}, \\
N &= \begin{bmatrix} 147.1842 & 0 & 0 \\ 583.8634 & 10.3713 & 0 \\ -35.8151 & 6.2819 & -0.0566 \end{bmatrix}, \\
A_{K11} &= \begin{bmatrix} -2.8619 & 0.0409 & 0.0001 \\ 2.4592 & -0.7117 & -0.0045 \\ -156.8730 & -24.7808 & -0.1452 \end{bmatrix}, \\
A_{K12} &= \begin{bmatrix} -2.9847 & -0.0340 & 0.0005 \\ 4.6122 & 0.2621 & -0.0369 \\ 131.9765 & 98.6897 & 2.4439 \end{bmatrix}, \\
A_{K21} &= \begin{bmatrix} -2.8506 & 0.0360 & -0.0005 \\ 3.7602 & -0.3604 & 0.0351 \\ -176.8456 & -110.8960 & -2.5693 \end{bmatrix}, \\
A_{K22} &= \begin{bmatrix} -2.9716 & -0.0410 & -0.0002 \\ 6.2141 & 0.4634 & 0.0015 \\ 114.9717 & 8.7115 & 0.0451 \end{bmatrix}, \\
B_{K1} &= \begin{bmatrix} -0.3601 & 0.0509 \\ 0.5596 & -0.3863 \\ -18.8758 & -0.9996 \end{bmatrix}, \\
B_{K2} &= \begin{bmatrix} -0.3550 & 0.0510 \\ 0.8055 & -0.3698 \\ 14.2606 & -0.6685 \end{bmatrix}, \\
C_{K1} &= \begin{bmatrix} -222.5433 & 2.7100 & 0.0110 \end{bmatrix}, \\
C_{K2} &= \begin{bmatrix} -231.8686 & -2.9150 & -0.0127 \end{bmatrix}, \\
D_K &= \begin{bmatrix} -22.2548 & 3.4606 \end{bmatrix}.
\end{aligned}$$

Note that, in order to avoid the singular solution, the following additional constraint has been added when solving the conditions of Theorem 2,

$$\left\| \begin{bmatrix} \hat{A}(h, h) & \hat{B}(h) \\ \hat{C}(h) & \hat{D} \end{bmatrix} \right\| \leq \delta,$$

where  $\delta = 70$ , which can be written as

$$\begin{aligned}
\Upsilon_{ii} &\geq 0, \quad i = 1, \dots, q, \\
\Upsilon_{ij} + \Upsilon_{ji} &\geq 0, \quad 1 \leq i < j \leq q,
\end{aligned}$$

where

$$\Upsilon_{ij} = \begin{bmatrix} \delta I_n & 0 & \hat{A}_{ij} & \hat{B}_i \\ * & \delta I_m & \hat{C}_i & \hat{D} \\ * & * & \delta I_n & 0 \\ * & * & * & \delta I_p \end{bmatrix}.$$

To solve the above problems we used CVX, a package for specifying and solving convex programs [43], [44].

**Simulation results.** For simulation, an actuator fault  $f(k)$  is created as

$$f(k) = \begin{cases} 0 & 0s \leq t < 200s \\ & (0 \leq k < 100) \\ 2(1 - e^{-0.05(t-200)}) & 200s \leq t \leq 1000s \\ & (100 \leq k \leq 500) \end{cases}.$$

Under initial value  $[0 \ 0 \ 5]^T$ , simulation results are displayed as follows. In the following simulation results, we apply the proposed design method to the original nonlinear system, instead of T-S fuzzy models, whose purpose is to verify the robustness of the proposed method with respect to modeling errors. Simulation results for the system controlled output responses are shown in Figure 2 (a 10s detection delay is considered). Figures 3–5 show simulation results of state responses. Figure 6 illustrates FE simulation result.




Fig. 2. Controlled output responses of  $z_L(k)$  (without FA: dotted line; under FA: solid line).




Fig. 3. State responses of  $x_1(k)$  (without FA: dotted line; under FA: solid line).

From the above simulation results, we can see that, despite the fact that  $\text{rank}(C_i B_i) = m$  is not satisfied and the open-loop system is unstable, the proposed design still achieves the performance under actuator faults, and the stability performance of the closed-loop system is guaranteed by the fuzzy DOFTC. Since the property of the presented example, the effect of the fault on the third state  $x_3(k)$  is more obvious




Fig. 4. State responses of  $x_2(k)$  (without FA: dotted line; under FA: solid line).




Fig. 6. Fault  $f(k)$  (dotted line) and its estimate  $\hat{f}(k)$  (solid line).




Fig. 5. State responses of  $x_3(k)$  (without FA: dotted line; under FA: solid line).

than the others. Note that the proposed fuzzy RFEO design can achieve asymptotical estimation for constant faults.

## VI. CONCLUSIONS

In this paper, a design framework for integrated robust FE and FA is developed for a class of discrete-time nonlinear systems described by a T-S fuzzy model. The framework includes a reduced-order FE observer and a dynamic output feedback fault tolerant controller to guarantee given stability requirements. Simulation results of a discrete-time nonlinear truck-trailer model are used to show the effectiveness of the obtained results. The issue of T-S fuzzy systems subject to unmeasurable premise variables [9], [45] and the extension of the proposed design to general nonlinear systems [46], [47] are interesting and practical, which will be studied in our future work.

## ACKNOWLEDGEMENT

The authors would like to thank the Associate Editor and reviewers for their comments and suggestions which have helped us to improve the presentation of the paper.

## REFERENCES

- [1] J. Chen and R. J. Patton, *Robust Model-Based Fault Diagnosis for Dynamic Systems*. Norwell, MA, USA: Kluwer Academic Publishers, 1999.
- [2] M. Blanke, M. Kinnaert, J. Lunze, and M. Staroswiecki, *Diagnosis and Fault-Tolerant Control*. Secaucus, NJ, USA: Springer-Verlag New York, Inc., 2006.
- [3] S. X. Ding, *Model-Based Fault Diagnosis Techniques: Design Schemes, Algorithms, and Tools*. Berlin, Heidelberg: Springer Publishing Company, Inc., 2008.
- [4] P. M. Frank, S. X. Ding, and B. Köppen-Seliger, "Current developments in the theory of FDI," in *Proceedings of IFAC Safeprocess*, Budapest, Hungary, 2000, pp. 16–27.
- [5] M. Kinnaert, "Fault diagnosis based on analytical models for linear and nonlinear systems – A tutorial," in *Proceedings of IFAC Safeprocess*, Washington, USA, 2003, pp. 37–50.
- [6] M. Staroswiecki, "On fault handling in control systems," *International Journal of Control, Automation, and Systems*, vol. 6, no. 3, pp. 296–305, 2008.
- [7] X. J. Ma, Z. Q. Sun, and Y. Y. He, "Analysis and design of fuzzy controller and fuzzy observer," *IEEE Transactions on Fuzzy Systems*, vol. 6, no. 1, pp. 41–51, 1998.
- [8] Y. Y. Cao and P. M. Frank, "Stability analysis and synthesis of nonlinear time-delay systems via linear Takagi-Sugeno fuzzy models," *Fuzzy Sets and Systems*, vol. 124, no. 2, pp. 213–229, 2001.
- [9] S. K. Nguang and P. Shi, " $H_\infty$  fuzzy output feedback control design for nonlinear systems: An LMI approach," *IEEE Transactions on Fuzzy Systems*, vol. 11, no. 3, pp. 331–340, 2003.
- [10] G. Feng, "A survey on analysis and design of model-based fuzzy control systems," *IEEE Transactions on Fuzzy Systems*, vol. 14, no. 5, pp. 676–697, 2006.
- [11] S. K. Nguang, P. Shi, and S. X. Ding, "Fault detection for uncertain fuzzy systems: An LMI approach," *IEEE Transactions on Fuzzy Systems*, vol. 15, no. 6, pp. 1251–1262, 2007.
- [12] H. Gao and T. Chen, "Stabilization of nonlinear systems under variable sampling: A fuzzy control approach," *IEEE Transactions on Fuzzy Systems*, vol. 15, no. 5, pp. 972–983, 2007.
- [13] Q. Kang, W. Wang, and Y. Liu, "Robust adaptive fuzzy control for a class of nonlinear interconnected systems," *International Journal of Innovative Computing, Information and Control*, vol. 5, no. 2, pp. 323–336, 2009.



- [14] Y. Yi and L. Guo, "Constrained PI tracking control for the output PDFs based on T-S fuzzy model," *International Journal of Innovative Computing, Information and Control*, vol. 5, no. 2, pp. 349–358, 2009.
- [15] J. Dong and G.-H. Yang, "Static output feedback  $H_\infty$  control of a class of nonlinear discrete-time systems," *Fuzzy Sets and Systems*, vol. 160, no. 19, pp. 2844–2859, 2009.
- [16] Y. Zhao, H. Gao, J. Lam, and B. Du, "Stability and stabilization of delayed T-S fuzzy systems: A delay partitioning approach," *IEEE Transactions on Fuzzy Systems*, vol. 17, no. 4, pp. 750–762, 2009.
- [17] B. Jiang, Z. Mao, and P. Shi, " $H_\infty$ -filter design for a class of networked control systems via T-S fuzzy-model approach," *IEEE Transactions on Fuzzy Systems*, vol. 18, no. 1, pp. 201–208, 2010.
- [18] X. Huang, K. Cao, X. Ban, and X.-Z. Gao, "Some further results on the stability analysis of a type of T-S fuzzy control systems in the frequency domain," *ICIC Express Letters*, vol. 4, no. 3(A), pp. 659–666, 2010.
- [19] H. Wu and M. Bai, "Stochastic stability analysis and synthesis for nonlinear fault tolerant control systems based on the T-S fuzzy model," *International Journal of Innovative Computing, Information and Control*, vol. 6, no. 9, pp. 3989–4000, 2010.
- [20] H. Wang and J. Lam, "Robust fault detection for uncertain discrete-time systems," *Journal of Guidance, Control, and Dynamics*, vol. 25, no. 2, pp. 291–301, 2002.
- [21] B. Jiang, M. Staroswiecki, and V. Cocquempot, " $H_\infty$  fault detection filter design for linear discrete-time systems with multiple time delays," *International Journal of Systems Science*, vol. 34, no. 5, pp. 365–373, 2003.
- [22] P. Zhang, S. X. Ding, G. Z. Wang, and D. H. Zhou, "Fault detection of linear discrete-time periodic systems," *IEEE Transactions on Automatic Control*, vol. 50, no. 2, pp. 239–244, 2005.
- [23] M. Zhong, H. Ye, S. X. Ding, and G. Wang, "Observer-based fast rate fault detection for a class of multirate sampled-data systems," *IEEE Transactions on Automatic Control*, vol. 52, no. 3, pp. 520–525, 2007.
- [24] Y. Zhao, J. Lam, and H. Gao, "Fault detection for fuzzy systems with intermittent measurements," *IEEE Transactions on Fuzzy Systems*, vol. 17, no. 2, pp. 398–410, 2009.
- [25] R. M.G. Ferrari, T. Parisini, and M. M. Polycarpou, "A fault detection and isolation scheme for nonlinear uncertain discrete-time systems," in *Proceedings of the 46th IEEE Conference on Decision and Control*, New Orleans, 2007, pp. 1009–1014.
- [26] —, "A robust fault detection and isolation scheme for a class of uncertain input-output discrete-time nonlinear systems," in *Proceedings of 2008 American Control Conference*, Seattle, 2008, pp. 2804–2809.
- [27] H. Wang and G.-H. Yang, "Fault estimations for uncertain linear discrete-time systems in low frequency domain," in *Proceedings of 2007 American Control Conference*, New York, 2007, pp. 1124–1129.
- [28] M. Saif, "Robust discrete time observer with application to fault diagnosis," *IEE Proceedings Control Theory and Applications*, vol. 145, no. 3, pp. 353–357, 1998.
- [29] B. Jiang and F. N. Chowdhury, "Fault estimation and accommodation for linear MIMO discrete-time systems," *IEEE Transactions on Control Systems Technology*, vol. 13, no. 3, pp. 493–499, 2005.
- [30] J. L. Chang, "Applying discrete-time proportional integral observers for state and disturbance estimations," *IEEE Transactions on Automatic Control*, vol. 51, no. 5, pp. 814–818, 2006.
- [31] Z. Gao, T. Breikin, and H. Wang, "Discrete-time proportional and integral observer and observer-based controller for systems with both unknown input and output disturbances," *Optimal Control Applications and Methods*, vol. 29, no. 3, pp. 171–189, 2008.
- [32] H. H. Choi, "LMI-based nonlinear fuzzy observer-controller design for uncertain MIMO nonlinear systems," *IEEE Transactions on Fuzzy Systems*, vol. 15, no. 5, pp. 956–971, 2007.
- [33] R. J. Patton, J. Chen, and C. J. Lopez-Toribio, "Fuzzy observers for nonlinear dynamic systems fault diagnosis," in *Proceedings of the 37th IEEE Conference on Decision and Control*, Tampa, 1998, pp. 84–89.
- [34] G. Garcia and J. Bernussou, "Pole assignment for uncertain systems in a specified disk by state feedback," *IEEE Transactions on Automatic Control*, vol. 40, no. 1, pp. 184–190, 1995.
- [35] M. Chilali and P. Gahinet, " $H_\infty$  design with pole placement constraints: An LMI approach," *IEEE Transactions on Automatic Control*, vol. 41, no. 3, pp. 358–367, 1996.
- [36] M. Chilali, P. Gahinet, and P. Apkarian, "Robust pole placement in LMI regions," *IEEE Transactions on Automatic Control*, vol. 44, no. 12, pp. 2257–2270, 1999.
- [37] S. Boyd, L. E. Ghaoui, E. Feron, and V. Balakrishnan, *Linear Matrix Inequalities in System and Control Theory*. Philadelphia: SIAM Studies in Applied Mathematics (vol. 15), 1994.
- [38] J. Li, H. O. Wang, D. Niemann, and K. Tanaka, "Dynamic parallel distributed compensation for Takagi-Sugeno fuzzy systems: An LMI approach," *Information Sciences*, vol. 123, no. 3–4, pp. 201–221, 2000.
- [39] C.-H. Fang, Y.-S. Liu, S.-W. Kau, L. Hong, and C.-H. Lee, "A new LMI-based approach to relaxed quadratic stabilization of T-S fuzzy control systems," *IEEE Transactions on Fuzzy Systems*, vol. 14, no. 3, pp. 386–397, 2006.
- [40] A. Sala and C. Ariño, "Asymptotically necessary and sufficient conditions for stability and performance in fuzzy control: Applications of Polya's theorem," *Fuzzy Sets and Systems*, vol. 158, no. 24, pp. 2671–2686, 2007.
- [41] K. Tanaka and M. Sano, "A robust stabilization problem of fuzzy control systems and its application to backing up control of a truck-trailer," *IEEE Transactions on Fuzzy Systems*, vol. 2, no. 2, pp. 119–134, 1994.
- [42] G. Feng and J. Ma, "Quadratic stabilization of uncertain discrete-time fuzzy dynamic systems," *IEEE Transactions on Circuits and Systems I: Fundamental Theory and Applications*, vol. 48, no. 11, pp. 1337–1344, 2001.
- [43] M. Grant and S. Boyd, "CVX: Matlab software for disciplined convex programming, version 1.21," <http://cvxr.com/cvx>, July 2010.
- [44] —, "Graph implementations for nonsmooth convex programs," *Recent Advances in Learning and Control (a tribute to M. Vidyasagar)*, vol. V. Blondel, S. Boyd, and H. Kimura, editors, pages 95–110, Lecture Notes in Control and Information Sciences, Springer, 2008. [http://stanford.edu/~boyd/graph\\_dcp.html](http://stanford.edu/~boyd/graph_dcp.html).
- [45] D. Ichalal, B. Marx, J. Ragot, and D. Maquin, "State estimation of Takagi-Sugeno systems with unmeasurable premise variables," *IET Control Theory and Applications*, vol. 4, no. 5, pp. 897–908, 2010.
- [46] Z. Gao, B. Jiang, P. Shi, and Y. Xu, "Fault accommodation for near space vehicle attitude dynamics via T-S fuzzy models," *International Journal of Innovative Computing, Information and Control*, vol. 6, no. 11, pp. 4843–4856, 2010.
- [47] Z. Gao, B. Jiang, R. Qi, Y. Xu, and Y. Cheng, "Fuzzy observer design for near space vehicle with application to sensor fault estimation," *ICIC Express Letters*, vol. 4, no. 1, pp. 177–182, 2010.




**Bin Jiang** was born in Jiangxi, China, in 1966. He obtained his Ph.D. degree in Automatic Control from Northeastern University, Shenyang, China, in 1995. He had since been a postdoctoral fellow or a research fellow in Singapore, France and the USA. Now he is a Professor and Vice Dean of the College of Automation Engineering in Nanjing University of Aeronautics and Astronautics, China. He currently serves as Associate Editor or Editorial Board Member for several international journals, such as *IEEE Trans. on Control Systems Technology*; *Int. J. of System Science*; *Int. J. of Control, Automation and Systems*; *Int. J. of Innovative Computing, Information and Control*. He is a senior member of IEEE, and a member of the IFAC Technical Committee on Fault Detection, Supervision, and Safety of Technical Processes. His research interests include fault diagnosis and fault-tolerant control and their applications.



**Ke Zhang** was born in Hebei province, China, in 1981. He received the B.Sc. degree in Automation from Hebei University of Science and Technology, Shijiazhuang, China, the M.Sc. degree in Control Theory and Engineering from Nanjing University of Aeronautics and Astronautics, Nanjing, China, in 2004 and 2007, respectively. From October 2009 to March 2010, he was a visiting student with Systèmes et applications des technologies de l'information et de l'énergie, Ecole Normale Supérieure de Cachan, France.

He is currently working towards the Ph.D. degree in Control Theory and Engineering with Nanjing University of Aeronautics and Astronautics. His research interests include fault diagnosis and fault tolerant control for dynamical systems and their applications.





**Peng Shi** received his B.Sc. degree in Mathematics from Harbin Institute of Technology, China in 1982; ME degree in Control Theory from Harbin Engineering University, China in 1985; Ph.D. degree in Electrical Engineering from the University of Newcastle, Australia in 1994; and Ph.D. degree in Mathematics from the University of South Australia in 1998. He was awarded the degree of Doctor of Science by the University of Glamorgan, UK, in 2006.

Dr. Shi was a lecturer in Heilongjiang University, China (1985–1989), in the University of South Australia (1997–1999) and a senior scientist in Defence Science and Technology Organisation, Department of Defence, Australia (1999–2005). He joined the University of Glamorgan, UK, as a professor in 2004. He has also been a professor at Victoria University, Australia since 2008. Dr. Shi's research interests include control system design, fault-detection techniques, Markov decision processes, and operational research. He has published a number of papers in these areas. In addition, Dr. Shi is a co-author of the three research monographs, *Analysis and Synthesis of Systems with Time-Delays* (with Y. Xia and M. Fu, Berlin, Springer, 2009), *Fuzzy Control and Filtering Design for Uncertain Fuzzy Systems* (with W. Assawinchaichote and S. K. Nguang, Berlin, Springer, 2006), and *Methodologies for Control of Jump Time-Delay Systems* (with M. Mahmoud, Boston, Kluwer, 2003). Dr. Shi currently serves as Editor-in-Chief of *Int. J. of Innovative Computing, Information and Control*. He is also an Advisory Board Member, Associate Editor and Editorial Board Member for a number of other international journals, including *IEEE Transactions on Automatic Control*, *IEEE Transactions on Systems, Man and Cybernetics* Part B, and *IEEE Transactions on Fuzzy Systems*. He is the recipient of the Most Cited Paper Award of Signal Processing in 2009. Dr. Shi is a Fellow of Institute of Mathematics and its Applications (UK), and a Senior Member of IEEE.